

BREWSTER

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1145

OWNER	NAME Bob McKenna		ADDRESS Brewster ny	
LOCATION OF WELL	(No. & Street) Rte. 22		(Town) (Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> FARM <input type="checkbox"/> TEST WELL <input type="checkbox"/> PUBLIC SUPPLY <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> OTHER (Specify) 530 S			
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY <input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) 193	DIAMETER (inches) 6"	WEIGHT PER FOOT 19 lb	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED DRIVE SHOE <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO    WAS CASING GRouted? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input type="checkbox"/> PUMPED <input checked="" type="checkbox"/> COMPRESSED AIR		HOURS 8	G.P.M. 5
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) Flowing		DURING YIELD TEST (feet) 620'	Depth of Completed Well in feet below Land surface: 620'
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	GRAVEL SIZE (inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET TO FEET		FORMATION DESCRIPTION	Sketch exact location of well with distances, to at least two permanent landmarks.
---	--	-----------------------	--

0	180	Fault Rock
180	620	Mica Shist

RECEIVED

FEB 2 1984

PUTNAM COUNTY  
DEPT. OF HEALTH

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

RECEIVED  
JAN 2 1984

JOHN H. PRINCESS, P.E.

DATE WELL COMPLETED 11-83	DATE OF REPORT 1-2-84	WELL DRILLER (Signature) Albert Nyant
------------------------------	--------------------------	--